



NOTES:

1. EXISTING GROUND AROUND AND ADJACENT TO WATER SERVICE SHALL BE COMPACTED TO PREVENT BREAKAGE OF INSULATION
2. INSULATION JOINTS SHALL BE STAGGERED
3. LOCATING SERVICE AND EXCAVATION ARE CONSIDERED INCIDENTAL
4. ADJUSTMENT OF CURB STOP (WHEN REQUIRED) SHALL BE PAID PER THE UNIT BID PRICE

305 - WATER SERVICE INSULATION

305 - Wat Serv Insul.dwg

6/2015

H:\Cad_Comm\Details Updated\0 - 300 - WATER\305 - Wat Serv Insul



1700 W 98TH ST.
BLOOMINGTON MN 55431
PHONE (952) 563-8700

PLATE NAME:

305 - Wat Serv Insul

**ENGINEERING DIVISION
PUBLIC WORKS DEPARTMENT**

LAST REVISED: 6/15/2015

LAST REVISED BY: KBO