



▲ PROVIDE SUPPORT ON DISCHARGE OF 1 1/2 AND 2" METER

NOTES:

1. OBSERVE CLEARANCES, PIPE ELEVATION RESTRICTIONS AND FULL FLOW VALVE REQUIREMENTS FOR ALL METER SIZES.
2. 2" AND SMALLER PIPE TO BE BRASS, COPPER, OR STAINLESS STEEL

321 - COMM. METER SETTING

321 - COMM. METER SETTING.DWG 9/2016

H:\CAD_COMN\Details Updated\300 - WATER\321 - Comm. Meter Setting



1700 W 98TH ST.
BLOOMINGTON MN 55431
PHONE (952) 563-8700

ENGINEERING DIVISION
PUBLIC WORKS DEPARTMENT

PLATE NAME:

321 - Comm. Meter Setting

LAST REVISED: 3/3/2023

LAST REVISED BY: KBO