

Pool name _____ Pool type Swim Spa Wading Zero-depth Plunge Therapy

Month _____ Year _____ Size of pool (Gallons) _____

Daily tests								Other tests		Maintenance			Comments Manual chem feed, breakdowns, injuries, accidents, CPO's initials
Date	Free Cl ₂ 0.5 - 5.0 ppm	Total Cl ₂	Comb. Cl ₂ <0.5 ppm	pH 7.2 - 8.0	Temp. Max. 104°	Flow rate GPM	Main suction outlet Close pool if loose, missing or broken. Initial.	Alk. >50 ppm	CYA <100 ppm	Back wash	Press. PSI	Other (e.g. H ₂ O added)	
1													
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30													
31													