

Motor Vehicle Exhibition Requirements Information Sheet

Motor vehicles on display within an enclosed structure shall comply with the following:

- a) Batteries are disconnected.
- b) Fuel in fuel tanks does not exceed one-quarter tank or 5 gallons (19L) (whichever is least).
- c) Fuel tanks and fill openings are closed and sealed to prevent tampering.
- d) Vehicles, boats or other motorcraft equipment are not fueled or defueled within the building.
- e) Motor vehicles shall not be moved during show hours or when the general public is present.
- f) Approved aisles and a means of egress shall be maintained throughout the exhibition area.

Note: A Temporary Fire Marshal Permit shall be obtained for each event. The fee for this permit is \$50.

Questions?

Contact the Fire Prevention Division
at 952-563-8933

