

VALVE BOX TO BE VERTICAL AND STRAIGHT ALLOWING A 4" PVC PIPE TO SLIDE FROM THE TOP DOWN AND OVER THE OPERATING NUT. ADD OPERATING STEM EXTENSION WHERE NECESSARY TO BRING OPERATING NUT TO 5 TO 9 FEET BELOW GRADE. ATTACH WITH A MINIMUM OF TWO ½" SET BOLTS

302 - TYPICAL VALVE INSTALLATION 302 - Valve (RSGV).dwg 6/2015

H:\CAD_COMN\Details Updated\300 - WATER\302 - Valve (RSCV)
PLATE NAME:



1700 W 98TH ST. BLOOMINGTON MN 55431 PHONE (952) 563-8700

302 - Valve (RSGV)

ENGINEERING DIVISION PUBLIC WORKS DEPARTMENT LAST REVISED: 2/24/2023 LAST REVISED BY: KBO