


TOP VIEW



SECTION VIEW

- NOTES:  
 -BLOCKING TO BE POURED CONCRETE,  
 MNDOT MIX DESIGN 3A32.  
 -FITTINGS MUST BE COVERED W/POLY  
 (8 MIL) PRIOR TO POURING CONCRETE.

312 - THRUST BLOCK DETAIL (SPECIAL)

312 - Thrust Blk (Special).dwg

6/2015

H:\Cad\_Comm\Details Updated\0 - 300 - WATER\312 - Thrust Blk (Special)

**CITY OF BLOOMINGTON MINNESOTA**  
 1700 W 98TH ST.  
 BLOOMINGTON MN 55431  
 PHONE (952) 563-8700

**ENGINEERING DIVISION  
 PUBLIC WORKS DEPARTMENT**

PLATE NAME:

**312 - Thrust Blk (Special)**

LAST REVISED: 6/15/2015

LAST REVISED BY: KBO