



1. ALL JOINTS SHALL BE RESTRAINED WITH EBAA IRON MEGALUG OR APPROVED EQUAL.
2. NO WATERMAIN SHALL BE RODDED UNDER ANY CIRCUMSTANCE.
3. ALL EXPOSED WATERMAIN SHALL BE WRAPPED WITH POLYETHYLENE IN ACCORDANCE WITH AWWA C-105.
4. INSULATION AND FOUNDATION MATERIAL SHALL EXTEND IN BOTH DIRECTIONS A MIN. OF 3' BEYOND THE STORM SEWER & WATERMAIN.
5. MECHANICAL JOINT OFFSET MAY BE USED IF AMOUNT OF OFFSET IS 18" OR LESS.
6. CONDUCTIVITY ACROSS JOINTS IS REQUIRED.
7. INSTALL INSULATION WITH OVERLAPPING JOINTS.
8. LENGTH OF JOINT RESTRAINT TO CONFORM TO DIPRA REQUIREMENTS CONCRETE ANCHOR BLOCKS MAY BE REQUIRED AT VERTICAL BENDS.

317 - WM ALTERATION 2  
317 - WM ALTERATION 2.DWG 9/2016

H:\Cad\_Comn\Details Updated\0 - 300 - WATER\317 - WM Alteration 2

**CITY OF BLOOMINGTON MINNESOTA**  
 1700 W 98TH ST.  
 BLOOMINGTON MN 55431  
 PHONE (952) 563-8700

**ENGINEERING DIVISION  
 PUBLIC WORKS DEPARTMENT**

PLATE NAME:

**317 - WM Alteration 2**

LAST REVISED: 9/16/2016

LAST REVISED BY: KBO