



▲ PROVIDE SUPPORT ON DISCHARGE OF 1 1/2 AND 2" METER
 OBSERVE CLEARANCES, PIPE ELEVATION RESTRICTIONS AND
 FULL FLOW VALVE REQUIREMENTS FOR ALL METER SIZES.
 2" AND SMALLER PIPE TO BE BRASS OR STAINLESS STEEL

321 - COMM. METER SETTING
 321 - COMM. METER SETTING.DWG 9/2016

H:\Cad_Cmn\Details Updated\0 - 300 - WATER\321 - Comm. Meter Setting

CITY OF BLOOMINGTON MINNESOTA
 1700 W 98TH ST.
 BLOOMINGTON MN 55431
 PHONE (952) 563-8700

**ENGINEERING DIVISION
 PUBLIC WORKS DEPARTMENT**

PLATE NAME:

321 - Comm. Meter Setting

LAST REVISED: 9/16/2016

LAST REVISED BY: KBO